

DuraVent Approval for Rinnai Boilers

The purpose of this technical bulletin is to announce the certification of M&G Duravent PolyPro and PolyPro Flex for use with Rinnai Condensing Boilers.

The following Duravent products are approved for use with Rinnai boilers:

- 2"/3" diameter PPS (lengths and elbows)
- 2"/3" Twin Pipe Termination (2/3 PPS-HTPL)
- 2" and 3" Single Pipe Termination (2/3 PPS-HSTL)
- 2"x4" and 3"x5" Concentric Horizontal Termination Kit (2/3 PPS-HKL)
- 2"x4" and 3"x5" Concentric Vertical Termination Kit (2/3 PPS-VKL)
- 2"/3" Flex Chimney Lining Kit (2/3 PPS-FKL)
- 2"/3" Flex Pipe (2/3 PPS-FLEX XX)



MAXIMUM EQUIVALENT VENT RUN

BOILER TYPE	VENT TYPE			
	2" / 2" x 4" Concentric	2" / 2" x 4" Concentric	2" Flex	3" Flex
E Series	40ft	100ft	20ft	50ft
Q85S Q130S QP85 QP130	40ft	100ft	20ft	50ft
Q175S Q175C	*	80ft	*	40ft
Q205S	*	40ft	*	20ft

* Not permitted for this model

